

Division: XFD                      Location: 432/D030  
Date of Inspection 7/7/05  
Inspected by: Jeff Alicz and Jin Wang

The following items were identified as needing corrective action:

1. Reminder: Access to the eyewash station needs to be kept clear at all times (see photo below).



2. Tool testing needs to be done on the heat gun. You may borrow a tool tester from the ES&H Coordinator's office.
3. The solvent waste needs to be disposed of in the red safety cans.
4. Recommendation: Arrangements should be made to have the network cables removed if not in use (see photo below).



\*\*\*\* PLEASE SEND A REPLY EMAIL INDICATING THE CORRECTIVE ACTIONS TAKEN.